

January 26, 2024

John Cable
Triangle
17855 Elk Prairie Drive
P.O. Box 1026
Rolla, MO 65402
TEL: (573) 364-1864
FAX: (573) 364-4782



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: RPS-Rolla High School

WorkOrder: 24010253

Dear John Cable:

TEKLAB, INC received 60 samples on 1/3/2024 12:57:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Elizabeth A. Hurley
Director of Customer Service
(618)344-1004 ex 33
ehurley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Quality Control Results	9
Receiving Check List	15
Chain of Custody	Appended

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



Case Narrative

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com



Accreditations

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24010253-001A	121-A	NELAP		0.0010	0.0034	mg/L	1	01/15/2024 11:48	12/30/2023 10:00
24010253-002A	121-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 11:59	12/30/2023 10:00
24010253-003A	122-A	NELAP		0.0010	0.0063	mg/L	1	01/15/2024 12:03	12/30/2023 10:00
24010253-004A	122-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:06	12/30/2023 10:00
24010253-005A	123-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:10	12/30/2023 10:00
24010253-006A	123-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:14	12/30/2023 10:00
24010253-007A	124-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:17	12/30/2023 10:00
24010253-008A	124-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:21	12/30/2023 10:00
24010253-009A	125-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:36	12/30/2023 10:00
24010253-010A	125-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:47	12/30/2023 10:00
24010253-011A	126-A	NELAP		0.0010	0.0011	mg/L	1	01/15/2024 12:50	12/30/2023 10:00
24010253-012A	126-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:54	12/30/2023 10:00
24010253-013A	127-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 12:58	12/30/2023 10:00
24010253-014A	127-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 13:01	12/30/2023 10:00
24010253-015A	128-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 13:05	12/30/2023 10:00
24010253-016A	128-B	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 13:09	12/30/2023 10:00
24010253-017A	129-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 13:23	12/30/2023 10:00
24010253-018A	129-B	NELAP		0.0010	0.0057	mg/L	5	01/13/2024 9:29	12/30/2023 10:00
24010253-019A	130-A	NELAP		0.0010	< 0.0010	mg/L	1	01/15/2024 13:27	12/30/2023 10:00
24010253-020A	130-B	NELAP		0.0010	0.0050	mg/L	1	01/15/2024 13:38	12/30/2023 10:00
24010253-021A	131-A	NELAP		0.0010	0.0060	mg/L	1	01/15/2024 13:42	12/30/2023 10:00
24010253-022A	131-B	NELAP		0.0010	0.0020	mg/L	1	01/15/2024 13:45	12/30/2023 10:00
24010253-023A	132-A	NELAP		0.0010	0.0036	mg/L	1	01/16/2024 14:42	12/30/2023 10:00
24010253-024A	132-B	NELAP		0.0010	0.0027	mg/L	1	01/16/2024 15:06	12/30/2023 10:00
24010253-025A	133-A	NELAP		0.0010	0.0041	mg/L	1	01/16/2024 14:46	12/30/2023 10:00
24010253-026A	133-B	NELAP		0.0010	0.0019	mg/L	1	01/16/2024 14:50	12/30/2023 10:00
24010253-027A	134-A	NELAP		0.0010	0.0026	mg/L	1	01/16/2024 14:54	12/30/2023 10:00
24010253-028A	134-B	NELAP		0.0010	0.0013	mg/L	1	01/16/2024 14:58	12/30/2023 10:00
24010253-029A	135-A	NELAP		0.0010	0.0025	mg/L	1	01/16/2024 15:02	12/30/2023 10:00
24010253-030A	135-B	NELAP		0.0010	0.0016	mg/L	1	01/15/2024 16:34	12/30/2023 10:00
24010253-031A	136-A	NELAP		0.0010	0.0059	mg/L	1	01/15/2024 16:38	12/30/2023 10:00
24010253-032A	136-B	NELAP		0.0010	0.0018	mg/L	1	01/15/2024 16:49	12/30/2023 10:00
24010253-033A	137-A	NELAP		0.0010	0.0057	mg/L	1	01/15/2024 16:52	12/30/2023 10:00
24010253-034A	137-B	NELAP		0.0010	0.0020	mg/L	1	01/15/2024 16:56	12/30/2023 10:00
24010253-035A	138-A	NELAP		0.0010	0.0038	mg/L	1	01/16/2024 15:31	12/30/2023 10:00
24010253-036A	138-B	NELAP		0.0010	0.0019	mg/L	1	01/19/2024 12:49	12/30/2023 10:00
24010253-037A	139-A	NELAP		0.0010	0.0021	mg/L	1	01/18/2024 23:01	12/30/2023 10:00
24010253-038A	139-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 23:31	12/30/2023 10:00
24010253-039A	140-A	NELAP		0.0010	0.0018	mg/L	1	01/18/2024 23:35	12/30/2023 10:00
24010253-040A	140-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 23:40	12/30/2023 10:00
24010253-041A	141-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 23:44	12/30/2023 10:00
24010253-042A	141-B	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 19:55	12/30/2023 10:00
24010253-043A	142-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 19:59	12/30/2023 10:00
24010253-044A	142-B	NELAP		0.0010	0.0111	mg/L	5	01/26/2024 4:33	12/30/2023 10:00
24010253-045A	143-A	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 20:03	12/30/2023 10:00
24010253-046A	143-B	NELAP		0.0010	0.0124	mg/L	5	01/26/2024 4:37	12/30/2023 10:00
24010253-047A	144-A	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 20:08	12/30/2023 10:00
24010253-048A	144-B	NELAP		0.0010	0.0382	mg/L	5	01/26/2024 4:41	12/30/2023 10:00



Laboratory Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24010253-049A	145-A	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 20:12	12/30/2023 10:00
24010253-050A	145-B	NELAP		0.0010	0.0295	mg/L	5	01/26/2024 4:45	12/30/2023 10:00
24010253-051A	146-A	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 23:48	12/30/2023 10:00
24010253-052A	146-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 20:16	12/30/2023 10:00
24010253-053A	147-A	NELAP		0.0010	0.0012	mg/L	1	01/18/2024 20:42	12/30/2023 10:00
24010253-054A	147-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 20:47	12/30/2023 10:00
24010253-055A	148-A	NELAP		0.0010	0.0045	mg/L	1	01/18/2024 20:51	12/30/2023 10:00
24010253-056A	148-B	NELAP		0.0010	0.0011	mg/L	1	01/18/2024 21:13	12/30/2023 10:00
24010253-057A	149-A	NELAP		0.0010	0.0113	mg/L	1	01/18/2024 20:55	12/30/2023 10:00
24010253-058A	149-B	NELAP		0.0010	0.0013	mg/L	1	01/18/2024 21:00	12/30/2023 10:00
24010253-059A	150-A	NELAP		0.0010	0.0083	mg/L	1	01/18/2024 21:04	12/30/2023 10:00
24010253-060A	150-B	NELAP		0.0010	< 0.0010	mg/L	1	01/18/2024 21:08	12/30/2023 10:00



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216968		SampType: MBLK		Units mg/L						
SampID: MBLK-216968										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/15/2024

Batch 216968		SampType: LCS		Units mg/L						
SampID: LCS-216968										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0504	0.0500	0	100.9	85	115	01/15/2024

Batch 216968		SampType: MS		Units mg/L						
SampID: 24010252-055AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010	E	0.109	0.1000	0.004268	105.0	70	130	01/15/2024

Batch 216968		SampType: MSD		Units mg/L						
SampID: 24010252-055AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0943	0.1000	0.004268	90.0	0.1093	14.74	01/15/2024

Batch 216968		SampType: MS		Units mg/L						
SampID: 24010253-001AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0929	0.1000	0.003423	89.5	70	130	01/15/2024

Batch 216968		SampType: MSD		Units mg/L						
SampID: 24010253-001AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0923	0.1000	0.003423	88.8	0.09294	0.74	01/15/2024

Batch 216969		SampType: MBLK		Units mg/L						
SampID: MBLK-216969										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/15/2024

Batch 216969		SampType: LCS		Units mg/L						
SampID: LCS-216969										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0504	0.0500	0	100.9	85	115	01/15/2024



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216969		SampType: MS		Units mg/L							
SampID: 24010253-009AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.103	0.1000	0.0007350	101.8	70	130	01/15/2024	

Batch 216969		SampType: MSD		Units mg/L							
SampID: 24010253-009AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0962	0.1000	0.0007350	95.5	0.1026	6.38	01/15/2024	

Batch 216969		SampType: MS		Units mg/L							
SampID: 24010253-019AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0880	0.1000	0.0005680	87.5	70	130	01/15/2024	

Batch 216969		SampType: MSD		Units mg/L							
SampID: 24010253-019AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0957	0.1000	0.0005680	95.2	0.08802	8.41	01/15/2024	

Batch 216972		SampType: MBLK		Units mg/L							
SampID: MBLK-216972											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/15/2024	

Batch 216972		SampType: LCS		Units mg/L							
SampID: LCS-216972											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0504	0.0500	0	100.9	85	115	01/15/2024	

Batch 216972		SampType: MS		Units mg/L							
SampID: 24010253-024AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0944	0.1000	0.002680	91.7	70	130	01/16/2024	

Batch 216972		SampType: MSD		Units mg/L							
SampID: 24010253-024AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0935	0.1000	0.002680	90.8	0.09438	0.92	01/16/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 216972		SampType: MS		Units mg/L						
SampID: 24010253-031AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.0968	0.1000	0.005858	91.0	70	130	01/15/2024

Batch 216972		SampType: MSD		Units mg/L						
SampID: 24010253-031AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.0964	0.1000	0.005858	90.6	0.09682	0.41	01/15/2024

Batch 217075		SampType: MBLK		Units mg/L						
SampID: MBLK-217075										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/13/2024

Batch 217075		SampType: LCS		Units mg/L						
SampID: LCS-217075										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.483	0.5000	0	96.6	85	115	01/15/2024

Batch 217075		SampType: MS		Units mg/L						
SampID: 23122148-013AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.491	0.5000	0.001240	98.0	70	130	01/13/2024

Batch 217075		SampType: MSD		Units mg/L						
SampID: 23122148-013AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010		0.490	0.5000	0.001240	97.7	0.4910	0.26	01/13/2024

Batch 217075		SampType: MS		Units mg/L						
SampID: 24010257-018AMS										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed
Lead		0.0010		0.499	0.5000	0.003395	99.1	70	130	01/13/2024

Batch 217075		SampType: MSD		Units mg/L						
SampID: 24010257-018AMSD										
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed
Lead		0.0010	E	0.501	0.5000	0.003395	99.4	0.4988	0.37	01/13/2024



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217083		SampType: MBLK		Units mg/L							
SampID: MBLK-217083										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 217083		SampType: LCS		Units mg/L							
SampID: LCS-217083										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010		0.0500	0.0500	0	100.0	85	115	01/17/2024	

Batch 217083		SampType: MS		Units mg/L							
SampID: 24010215-007AMS										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010	E	0.115	0.1000	0.01980	95.7	70	130	01/19/2024	

Batch 217083		SampType: MSD		Units mg/L							
SampID: 24010215-007AMSD										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD		
Lead		0.0010	E	0.112	0.1000	0.01980	92.6	0.1155	2.69	01/19/2024	

Batch 217083		SampType: MS		Units mg/L							
SampID: 24010253-036AMS										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010	E	0.103	0.1000	0.001853	101.2	70	130	01/19/2024	

Batch 217083		SampType: MSD		Units mg/L							
SampID: 24010253-036AMSD										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD		
Lead		0.0010	E	0.103	0.1000	0.001853	101.2	0.1031	0.02	01/19/2024	

Batch 217085		SampType: MBLK		Units mg/L							
SampID: MBLK-217085										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/17/2024	

Batch 217085		SampType: LCS		Units mg/L							
SampID: LCS-217085										Date Analyzed	
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit		
Lead		0.0010		0.0500	0.0500	0	100.0	85	115	01/17/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217085		SampType: MS		Units mg/L							
SampID: 24010253-052AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.112	0.1000	0.0004347	111.5	70	130	01/18/2024	

Batch 217085		SampType: MSD		Units mg/L							
SampID: 24010253-052AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0950	0.1000	0.0004347	94.6	0.1120	16.33	01/18/2024	

Batch 217085		SampType: MS		Units mg/L							
SampID: 24010253-056AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.0800	0.1000	0.001144	78.9	70	130	01/18/2024	

Batch 217085		SampType: MSD		Units mg/L							
SampID: 24010253-056AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.0785	0.1000	0.001144	77.3	0.08002	1.92	01/18/2024	

Batch 217640		SampType: MBLK		Units mg/L							
SampID: MBLK-217640											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		< 0.0010	0.0002	0	0	-100	100	01/26/2024	

Batch 217640		SampType: LCS		Units mg/L							
SampID: LCS-217640											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.476	0.5000	0	95.2	85	115	01/26/2024	

Batch 217640		SampType: MS		Units mg/L							
SampID: 24010250-048AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010		0.459	0.5000	0.002802	91.3	70	130	01/26/2024	

Batch 217640		SampType: MSD		Units mg/L							
SampID: 24010250-048AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010		0.468	0.5000	0.002802	93.0	0.4595	1.81	01/26/2024	



Quality Control Results

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)

Batch 217640		SampType: MS		Units mg/L							
SampID: 24010251-032AMS											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	Low Limit	High Limit	Date Analyzed	
Lead		0.0010	E	0.891	1.000	0.002569	88.9	70	130	01/26/2024	

Batch 217640		SampType: MSD		Units mg/L							
RPD Limit: 20											
SampID: 24010251-032AMSD											
Analyses	Cert	RL	Qual	Result	Spike	SPK Ref Val	%REC	RPD Ref Val	%RPD	Date Analyzed	
Lead		0.0010	E	0.931	1.000	0.002569	92.9	0.8914	4.38	01/26/2024	



Receiving Check List

<http://www.teklabinc.com/>

Client: Triangle

Work Order: 24010253

Client Project: RPS-Rolla High School

Report Date: 26-Jan-24

Carrier: John Cable

Received By: LEH

Completed by:

Amber Dilallo

Reviewed by:

Ellie Hopkins

On:

03-Jan-24

Amber Dilallo

On:

03-Jan-24

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- | | | | | |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C N/A |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

- | | | | |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

CHAIN OF CUSTODY

TEKLAB INC. 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (613) 344-1004 Fax (618) 344-1005

Client: <u>TRIANGLE ENVIRONMENTAL SCIENCE AND ENGINEERING</u> Address: <u>PO BOX 1026</u> City/State/Zip: <u>ROLLA, MO 65402</u> Contact: <u>JOHN CABLE</u> Phone: <u>573 308 0140</u> Email: <u>TRIANGLE.ENVIRONMENTAL</u> Fax: <u>@GMAIL.COM</u>				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input checked="" type="checkbox"/> NO ICE <u>NA</u> °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES: Client Comments:			
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No							
PROJECT NAME/NUMBER <u>RPS-Rolla High School</u>		SAMPLE COLLECTOR'S NAME JOHN W CABLE		# and Type of Containers UNP HNO3 NaOH H2SO4 HCL MeOH NaHSO4 TSP Other		INDICATE ANALYSIS REQUESTED	
RESULTS REQUESTED <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		BILLING INSTRUCTIONS TRIANGLE					
Lab Use Only	Sample ID	Date/Time Sampled	Matrix				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
			Drinking Water				
Relinquished By		Date/Time		Received By		Date/Time	
JOHN W CABLE <i>John W Cable</i> <u>1-3-24</u> <u>12:57</u>		<u>1/2/24 @</u>		<i>John W Cable</i>		<u>1/3/24 12:57</u>	

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

24010249

001	1-A	DRINKING WATER	LEAD	12/30/23 @ 1000
002	1-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	2-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	2-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	3-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	3-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	4-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	4-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	5-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	5-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	6-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	6-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	7-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	7-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	8-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	8-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	9-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	9-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	10-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	10-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	11-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	11-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	12-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	12-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	13-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	13-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	14-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	14-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	15-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	15-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	16-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	16-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	17-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	17-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	18-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	18-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	19-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	19-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	20-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	20-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	21-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	21-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	22-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	22-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	23-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	23-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	24-A	DRINKING WATER	LEAD	12/30/23 @ 1000

241010249

048	24-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	25-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	25-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	26-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	26-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	27-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	27-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	28-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	28-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	29-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	29-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	30-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	30-B	DRINKING WATER	LEAD	12/30/23 @ 1000
241010250	31-A	DRINKING WATER	LEAD	12/30/23 @ 1000
001	31-B	DRINKING WATER	LEAD	12/30/23 @ 1000
003	32-A	DRINKING WATER	LEAD	12/30/23 @ 1000
004	32-B	DRINKING WATER	LEAD	12/30/23 @ 1000
005	33-A	DRINKING WATER	LEAD	12/30/23 @ 1000
006	33-B	DRINKING WATER	LEAD	12/30/23 @ 1000
007	34-A	DRINKING WATER	LEAD	12/30/23 @ 1000
008	34-B	DRINKING WATER	LEAD	12/30/23 @ 1000
009	35-A	DRINKING WATER	LEAD	12/30/23 @ 1000
010	35-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	36-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	36-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	37-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	37-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	38-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	38-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	39-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	39-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	40-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	40-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	41-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	41-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	42-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	42-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	43-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	43-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	44-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	44-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	45-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	45-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	46-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	46-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	47-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	47-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010250

035	48-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	48-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	49-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	49-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	50-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	50-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	51-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	51-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	52-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	52-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	53-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	53-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	54-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	54-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	55-A	DRINKING WATER	LEAD	12/30/23 @ 1000
051	56-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	56-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	57-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	57-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	58-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	58-B	DRINKING WATER	LEAD	12/30/23 @ 1000
057	59-A	DRINKING WATER	LEAD	12/30/23 @ 1000
058	59-B	DRINKING WATER	LEAD	12/30/23 @ 1000
059	60-A	DRINKING WATER	LEAD	12/30/23 @ 1000
060	60-B	DRINKING WATER	LEAD	12/30/23 @ 1000
061	61-A	DRINKING WATER	LEAD	12/30/23 @ 1000
062	61-B	DRINKING WATER	LEAD	12/30/23 @ 1000
063	62-A	DRINKING WATER	LEAD	12/30/23 @ 1000
064	62-B	DRINKING WATER	LEAD	12/30/23 @ 1000
065	63-A	DRINKING WATER	LEAD	12/30/23 @ 1000
066	63-B	DRINKING WATER	LEAD	12/30/23 @ 1000
067	64-A	DRINKING WATER	LEAD	12/30/23 @ 1000
068	64-B	DRINKING WATER	LEAD	12/30/23 @ 1000
069	65-A	DRINKING WATER	LEAD	12/30/23 @ 1000
070	65-B	DRINKING WATER	LEAD	12/30/23 @ 1000
071	66-A	DRINKING WATER	LEAD	12/30/23 @ 1000
072	66-B	DRINKING WATER	LEAD	12/30/23 @ 1000
073	67-A	DRINKING WATER	LEAD	12/30/23 @ 1000
074	67-B	DRINKING WATER	LEAD	12/30/23 @ 1000
075	68-A	DRINKING WATER	LEAD	12/30/23 @ 1000
076	68-B	DRINKING WATER	LEAD	12/30/23 @ 1000
077	69-A	DRINKING WATER	LEAD	12/30/23 @ 1000
078	69-B	DRINKING WATER	LEAD	12/30/23 @ 1000
079	70-A	DRINKING WATER	LEAD	12/30/23 @ 1000
080	70-B	DRINKING WATER	LEAD	12/30/23 @ 1000
081	71-A	DRINKING WATER	LEAD	12/30/23 @ 1000
082	71-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010251			
013	72-A	DRINKING WATER LEAD	12/30/23 @ 1000
014	72-B	DRINKING WATER LEAD	12/30/23 @ 1000
015	73-A	DRINKING WATER LEAD	12/30/23 @ 1000
016	73-B	DRINKING WATER LEAD	12/30/23 @ 1000
027	74-A	DRINKING WATER LEAD	12/30/23 @ 1000
028	74-B	DRINKING WATER LEAD	12/30/23 @ 1000
029	75-A	DRINKING WATER LEAD	12/30/23 @ 1000
030	75-B	DRINKING WATER LEAD	12/30/23 @ 1000
031	76-A	DRINKING WATER LEAD	12/30/23 @ 1000
032	76-B	DRINKING WATER LEAD	12/30/23 @ 1000
033	77-A	DRINKING WATER LEAD	12/30/23 @ 1000
034	77-B	DRINKING WATER LEAD	12/30/23 @ 1000
035	78-A	DRINKING WATER LEAD	12/30/23 @ 1000
036	78-B	DRINKING WATER LEAD	12/30/23 @ 1000
037	79-A	DRINKING WATER LEAD	12/30/23 @ 1000
038	79-B	DRINKING WATER LEAD	12/30/23 @ 1000
039	80-A	DRINKING WATER LEAD	12/30/23 @ 1000
040	80-B	DRINKING WATER LEAD	12/30/23 @ 1000
041	81-A	DRINKING WATER LEAD	12/30/23 @ 1000
042	81-B	DRINKING WATER LEAD	12/30/23 @ 1000
043	82-A	DRINKING WATER LEAD	12/30/23 @ 1000
044	82-B	DRINKING WATER LEAD	12/30/23 @ 1000
045	83-A	DRINKING WATER LEAD	12/30/23 @ 1000
046	83-B	DRINKING WATER LEAD	12/30/23 @ 1000
047	84-A	DRINKING WATER LEAD	12/30/23 @ 1000
048	84-B	DRINKING WATER LEAD	12/30/23 @ 1000
049	85-A	DRINKING WATER LEAD	12/30/23 @ 1000
050	85-B	DRINKING WATER LEAD	12/30/23 @ 1000
051	86-A	DRINKING WATER LEAD	12/30/23 @ 1000
052	86-B	DRINKING WATER LEAD	12/30/23 @ 1000
053	87-A	DRINKING WATER LEAD	12/30/23 @ 1000
054	87-B	DRINKING WATER LEAD	12/30/23 @ 1000
055	88-A	DRINKING WATER LEAD	12/30/23 @ 1000
056	88-B	DRINKING WATER LEAD	12/30/23 @ 1000
057	89-A	DRINKING WATER LEAD	12/30/23 @ 1000
058	89-B	DRINKING WATER LEAD	12/30/23 @ 1000
059	90-A	DRINKING WATER LEAD	12/30/23 @ 1000
060	90-B	DRINKING WATER LEAD	12/30/23 @ 1000
24010252			
001	91-A	DRINKING WATER LEAD	12/30/23 @ 1000
002	91-B	DRINKING WATER LEAD	12/30/23 @ 1000
003	92-A	DRINKING WATER LEAD	12/30/23 @ 1000
004	92-B	DRINKING WATER LEAD	12/30/23 @ 1000
005	93-A	DRINKING WATER LEAD	12/30/23 @ 1000
006	93-B	DRINKING WATER LEAD	12/30/23 @ 1000
007	94-A	DRINKING WATER LEAD	12/30/23 @ 1000
008	94-B	DRINKING WATER LEAD	12/30/23 @ 1000
009	95-A	DRINKING WATER LEAD	12/30/23 @ 1000

24010252

010	95-B	DRINKING WATER	LEAD	12/30/23 @ 1000
011	96-A	DRINKING WATER	LEAD	12/30/23 @ 1000
012	96-B	DRINKING WATER	LEAD	12/30/23 @ 1000
013	97-A	DRINKING WATER	LEAD	12/30/23 @ 1000
014	97-B	DRINKING WATER	LEAD	12/30/23 @ 1000
015	98-A	DRINKING WATER	LEAD	12/30/23 @ 1000
016	98-B	DRINKING WATER	LEAD	12/30/23 @ 1000
017	99-A	DRINKING WATER	LEAD	12/30/23 @ 1000
018	99-B	DRINKING WATER	LEAD	12/30/23 @ 1000
019	100-A	DRINKING WATER	LEAD	12/30/23 @ 1000
020	100-B	DRINKING WATER	LEAD	12/30/23 @ 1000
021	101-A	DRINKING WATER	LEAD	12/30/23 @ 1000
022	101-B	DRINKING WATER	LEAD	12/30/23 @ 1000
023	102-A	DRINKING WATER	LEAD	12/30/23 @ 1000
024	102-B	DRINKING WATER	LEAD	12/30/23 @ 1000
025	103-A	DRINKING WATER	LEAD	12/30/23 @ 1000
026	103-B	DRINKING WATER	LEAD	12/30/23 @ 1000
027	104-A	DRINKING WATER	LEAD	12/30/23 @ 1000
028	104-B	DRINKING WATER	LEAD	12/30/23 @ 1000
029	105-A	DRINKING WATER	LEAD	12/30/23 @ 1000
030	105-B	DRINKING WATER	LEAD	12/30/23 @ 1000
031	106-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	106-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	107-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	107-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	108-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	108-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	109-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	109-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	110-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	110-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	111-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	111-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	112-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	112-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	113-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	113-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	114-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	114-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	115-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	115-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	116-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	116-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	117-A	DRINKING WATER	LEAD	12/30/23 @ 1000
054	117-B	DRINKING WATER	LEAD	12/30/23 @ 1000
055	118-A	DRINKING WATER	LEAD	12/30/23 @ 1000
056	118-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010252

057	119-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
058	119-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
059	120-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
060	120-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
24010253	061	121-A	DRINKING WATER	LEAD	12/30/23 @ 1000
061	121-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
063	122-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
064	122-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
065	123-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
066	123-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
067	124-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
068	124-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
069	125-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
070	125-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
071	126-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
072	126-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
073	127-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
074	127-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
075	128-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
076	128-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
077	129-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
078	129-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
079	130-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
080	130-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
081	131-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
082	131-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
083	132-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
084	132-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
085	133-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
086	133-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
087	134-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
088	134-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
089	135-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
090	135-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
091	136-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
092	136-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
093	137-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
094	137-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
095	138-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
096	138-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
097	139-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
098	139-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
099	140-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
100	140-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
101	141-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
102	141-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
103	142-A	DRINKING WATER	LEAD	12/30/23 @ 1000	

24010253

044	142-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
045	143-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
046	143-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
047	144-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
048	144-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
049	145-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
050	145-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
051	146-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
052	146-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
053	147-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
054	147-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
055	148-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
056	148-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
057	149-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
058	149-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
059	150-A	DRINKING WATER	LEAD	12/30/23 @ 1000	
060	150-B	DRINKING WATER	LEAD	12/30/23 @ 1000	
24010254	001	151-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	002	151-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	003	152-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	004	152-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	005	153-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	006	153-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	007	154-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	008	154-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	009	155-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	010	155-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	011	156-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	012	156-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	013	157-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	014	157-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	015	158-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	016	158-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	017	159-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	018	159-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	019	160-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	020	160-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	021	161-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	022	161-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	023	162-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	024	162-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	025	163-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	026	163-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	027	164-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	028	164-B	DRINKING WATER	LEAD	12/30/23 @ 1000
	029	165-A	DRINKING WATER	LEAD	12/30/23 @ 1000
	030	165-B	DRINKING WATER	LEAD	12/30/23 @ 1000

24010254

031	166-A	DRINKING WATER	LEAD	12/30/23 @ 1000
032	166-B	DRINKING WATER	LEAD	12/30/23 @ 1000
033	167-A	DRINKING WATER	LEAD	12/30/23 @ 1000
034	167-B	DRINKING WATER	LEAD	12/30/23 @ 1000
035	168-A	DRINKING WATER	LEAD	12/30/23 @ 1000
036	168-B	DRINKING WATER	LEAD	12/30/23 @ 1000
037	169-A	DRINKING WATER	LEAD	12/30/23 @ 1000
038	169-B	DRINKING WATER	LEAD	12/30/23 @ 1000
039	170-A	DRINKING WATER	LEAD	12/30/23 @ 1000
040	170-B	DRINKING WATER	LEAD	12/30/23 @ 1000
041	171-A	DRINKING WATER	LEAD	12/30/23 @ 1000
042	171-B	DRINKING WATER	LEAD	12/30/23 @ 1000
043	172-A	DRINKING WATER	LEAD	12/30/23 @ 1000
044	172-B	DRINKING WATER	LEAD	12/30/23 @ 1000
045	173-A	DRINKING WATER	LEAD	12/30/23 @ 1000
046	173-B	DRINKING WATER	LEAD	12/30/23 @ 1000
047	174-A	DRINKING WATER	LEAD	12/30/23 @ 1000
048	174-B	DRINKING WATER	LEAD	12/30/23 @ 1000
049	175-A	DRINKING WATER	LEAD	12/30/23 @ 1000
050	175-B	DRINKING WATER	LEAD	12/30/23 @ 1000
051	176-A	DRINKING WATER	LEAD	12/30/23 @ 1000
052	176-B	DRINKING WATER	LEAD	12/30/23 @ 1000
053	ICE-1	DRINKING WATER	LEAD	12/30/23 @ 1000
054	ICE-2	DRINKING WATER	LEAD	12/30/23 @ 1000